

# CLOSTER PUBLIC SCHOOLS

340 Homans Avenue • Closter, New Jersey 07624



201-768-3001 Ext. 41112  
Fax: 201-768-1903

E-mail: [villanuevaf@nvnet.org](mailto:villanuevaf@nvnet.org)  
Website: [www.closterschools.org](http://www.closterschools.org)

Floro M. Villanueva Jr.  
Business Administrator/Board Secretary

June 30, 2026

## **ADDENDUM NO. 1**

**RE: Interior and Exterior Door Replacement  
Hillside Elementary School and Tenakill Middle School  
Bid Opening: Wednesday, July 8, 2026, at 10:00 AM**

To All Prospective Bidders:

This is Addendum No. 1. It answers questions received about the bid. This Addendum is now part of the bid documents. All bidders must acknowledge this Addendum on the bid form.

### **1. Door Widths and Heights**

The bid specifications do not list door width or height. Bidders must field-verify all door and frame openings before submitting a bid. The District will not pay extra cost for any bidder who fails to field verify.

### **2. Alternates 1 through 5, Hardware and Cylindrical Locksets**

Alternates 1 through 5 cover Stock Room 2, Room B112, Room B220, Room B211, and Room B202 at Tenakill Middle School. Each Alternate is priced individually. All Alternates share the same hardware scope listed in the bid specifications. Existing cylindrical locksets shall be reused for Alternates 1 through 5. New locksets are not required.

### **3. Frame Jamb Depth and Anchors, Alternates 1 through 5**

The bid specifications do not list frame jamb depth or anchor type. Bidders must field verify wall thickness at each opening and supply frames to match. Anchors must suit the wall construction at each opening and follow manufacturer standards and NFPA 80.

All other terms and conditions of the bid remain the same.

Direct any questions about this Addendum to  
Floro M. Villanueva Jr.  
School Business Administrator/Board Secretary