



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	10/05/2026
Water System Name:	Frazier Mountain High School
Water System Number:	1503140
Water System Type:	☐ Community ☒ Non-Transient, Non Community
Monitoring Frequency:	☐ 6-month ☐ Annual ☒ Triennial
# of Samples Required:	5
# of Samples Reported:	5
90th Percentile Level (mg/L)	
Lead: <i>Action Level = 0.015 mg/L</i>	0.021
Copper: <i>Action Level = 1.3 mg/L</i>	0.165

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
01	7/23/26	Student Store / 14427 Lebec Rd., Lebec		0.038	0.130
02	7/23/26	Admin Hall / Same as above		0.003	ND
03	7/23/26	Cafeteria SF / Same as above		ND	0.009
04	7/23/26	Tennis Court / Same as above		ND	0.200
05	7/23/26	Boy's Locker / Same as above		0.004	ND
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. (Water System) is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.